



T&S BRASS AND BRONZE WORKS, INC. 2 Saddleback Cove / P.O. Box 1088 Travelers Rest, SC 29690

Model No.

EC-3102-SMT8

Item No.

Travelers Rest, SC: 800-476-4103 • Simi Valley, CA: 800-423-0150 • Fax: 864-834-3518 • www.tsbrass.com

Travelers Rest, SC. 600-470-4103 • Sinii Valley, CA. 600-423-0150 • Pax. 604-654-5516 • WWW.tsblass.com			
	ITEM NO.	SALES NO.	DESCRIPTION
-	1	B-0199-08	VR 2.2 GPM Aerator, 13/16-27 UN Male w/ Key
	2	017195-45	Angled Sensor w/ Cable
	3	018251-45	ChekPoint 8" C-C SMT Deck Plate
	4	018541-45	M4 x 20mm, SS, Torx VR FH Screw
	5	018249-45	Handle
	6	018248-45	Temperature Limit Stop
	7	EC-SMT	Above Deck Thermostatic Mixing Valve w/ Handle
	8	016297-45	Inlet Hose, Faucet, 1/2" NPSM-F x 1/4" NPSM-F
71	9	016647-45	ChekPoint Module (Blue)
2	10	EC-FILTER	Replacement Filter
	11	002534-25	Close Nipple, 1/2" NPT
	12	5EF-0002	Double Gang, Plug-in AC Transformer
1	13	016167-45	Supply Hose, 1/2" NPSM Female x 1/2" NPSM Female
	14	5EF-0005	Supply Hose, 9/16-24 Female x 1/2" NPSM
	ſ		A Maximum of (8) ChekPoint Faucets can be Hardwire Connected and Powered by EC-HARDWIRE ChekPoint Hardwire AC Transformer. (Sold Separately)
d ₁₄	10 11		Label for Flow Control Switch Settings is Located on Inside of Back Cover.
018543-45 015425-45			Flow Control Switches are Located Inside Module Housing in Black Box Next to Battery Compartment. *Switches are Set to DEFAULT Position: - Auto Time Out = 15 Seconds - Shut Off Delay = 1 Second - Auto Flush = OFF
VR Screw L-Key VR Aerator Key			Remove (4) Screws and Back Cover to
 *Available Water Flow Control Selections: Access Switches. - Auto Time Out: 15 sec, 30 sec, 45 sec, 60 sec, 3 min, 20 min - Shut Off Delay: 1 sec, 10 sec, 15 sec, 30 sec - Auto Flush (30 Seconds After Every 12 Inactive Hours): ON or OFF 			
Product Specifications:			Product Compliance:
Chrome Plated Brass Electronic Faucet Spout w/ 8" Centers Deck Plate, Above Adjustable Thermostatic Mixing Valve w AC/DC Control Module with Internal Flow 18" Long Hot & Cold Supply Stop Elevit	Deck // Integ w Con	Side Mount gral Check Val itrol Setting Sv	Ves, NSF 61 - Section 9 NSF 372 (Low Lead Content) vitches, ANSI A117.1 (ADA)
18" Long Hot & Cold Supply Stop Flexib			ASSE 1070 (TMV)
Drawn: DMH Checked: KJG Approved: JHB Date: 08/27/15 Scale: NTS Sheet: 2 of 3			