



T&S BRASS AND BRONZE WORKS, INC. 2 Saddleback Cove / P.O. Box 1088 Travelers Rest, SC 29690

Model No.

EC-3142-HG

Item No.

Travelers Rest, SC: 800-476-4103 • Simi Valley, CA: 800-423-0150 • Fax: 864-834-3518 • www.tsbrass.com

Travelers Rest, 30. 000-470-4103 • Simi valley, CA. 000-4		1 87. 004-004-001	
	ITEM NO.	SALES NO.	DESCRIPTION
	1	B-0199-08	VR 2.2 GPM Aerator, 13/16-27 UN Male w/ Key
	2	019087-45	6VDC Lithium Battery, CR-P2
	3	019088-45	Auxiliary Power Connector Cable
	4	018544-45	SS Flex Hose w/ Check Valve Adapter
	5	5EF-0002	Plug-In A/C Transformer
	6	019082-45	Lever Asm & Body Screw Kit w/ L-Key
	7	EC-HYDROGEN	HydroGenerator Power Supply
	8	017506-45	1/2" NPSM Swivel Coupling
	9	019086-45	Body Plug, Pre-Set Temperature
 Flow Control Switches are Located Behind the Sensor. Remove Battery to Access Switches. * Switches are set to DEFAULT position: Auto Time Out = 15 seconds Shut Off Delay = 1 second Auto Flush = OFF * Available Water Flow Control Selections: Auto Time Out: 15 sec, 30 sec, 45 sec, 60 sec, 3 min, 20 min Shut Off Delay: 1 sec, 10 sec, 15 sec, 30 sec Auto Flush (30 Seconds After Every 12 Inactive Hours): ON or OFF 			
	-(7)		Optional Plug Replaces Lever Handle When Pre-setting Temperature (Installs from Inside of Body)
	\bigcirc		
			25-45 018543-45 ator Key Torx T-20 VR L-Key
Product Specifications: Chrome Plated Brass Above Deck Electronics Fauc Mount, Cast Spout w/ 2.2 GPM VR Aerator, Point-of Control, Hydro-Generator Powered, 19" Flexible Sta Hoses & 3/8" Compression Inlets	f-Úse Ťe iinless S	emperature. Steel Supply	Product Compliance: ASME A112.18.1 / CSA B125.1 NSF 61 - Section 9 NSF 372 (Low Lead Content) ANSI A117.1 (ADA) UL 1951
Drawn: DMH Checked: JRM Approved:	JHB	Date: 11/22/1	6 Scale: NTS Sheet: 2 of 2